

Top 10 Fire Code Violations

1. Means of egress blocked, obstructed, or reduced




2. Exit signs/emergency egress lighting not operative



OUR CORE VALUES

Integrity • Fiscal Responsibility • Transparency • Outstanding Customer Service

3. Use of extension cords in place of permanent wiring/overloaded extension cords and power strips



4. No certificate of occupancy/or incorrect information on certificate of occupancy
5. Storage piled within 24" of ceiling (18" for a sprinklered building)



6. Address not visible from street
7. Additional locks installed on exit doors



8. Fire access roads inaccessible/not marked



9. Fire extinguishers not maintained, labelled, or mounted, or it is obstructed



10. Fire protection systems (fire alarm, sprinkler, hood suppression system) not maintained